

ADDENDUM #1



PROJECT: 2019 Rotary Park Arroyo Maintenance
BID NO: 19-004
FROM: John Malloy
DATE: 2-4-2019

Questions and Answers

- 1. Item 1.1 and the project drawings refer to cobble being used to reinforce banks and underlie sandstone reinforcements.*
Answer: Instead of using cobble, 6" angular rock should be used in these areas.
- 2. Question: "Is there a place to haul spoil materials? How far from site? Obviously we have to create room in bank before we install rock."*
Answer: The contractor should make arrangements for disposal of spoil materials.
- 3. Question: "Will City irrigate sod-or can we consider seeding impact areas?"*
Answer: City irrigation will commence in mid-April to allow for watering of new sod. Section 1.3.4 of the bid document discusses the use of sod for restoration.
- 4. Question: "Can we haul steel/wood to City dumpster- or pay at the dump?"*
Answer: The contractor should plan to haul off trash and debris as well as pay for all costs associated with this removal.

Acknowledgement in Receipt of Addendum

FIRM NAME: _____

BY:(Printed) _____

BY:(Signature) _____ TITLE: _____

Note: A signed acknowledgement in receipt of this addendum **MUST** be included with your bid proposal.