

ADDENDUM #3



PROJECT: Miami-Hillcrest Roundabout
BID NO: 19-005
FROM: Scott Murphy
DATE: February 19, 2019

Questions and Answers

1. *I am hearing from pipe suppliers that the 14" restrained joint pipe is either unavailable or cost-prohibitive. Could I bid these lines and associated fittings as a more common 16" pipe if necessary?*

Answer: Either 14" or 16" pipe would be acceptable for use on this project depending on availability. If utilizing the larger pipe please note this on the bid packet variances (Page 9) and bid all corresponding line items accordingly (e.g., costs of the associated larger gate valves, tees, etc). The cost for any additional reducers required to go from 14" to 16" (if applicable), should be included in the cost for the pipe.

Clarifications and Additions

1. None this addendum.

Plan Revisions

1. The quantity of detectable warning mats on the bid form was incorrect. The correct quantity is 58 each. **Please update the quantity of this line item (Item 67) to the correct quantity of 58 on the project bid form and submit the corrected form with your bid.**

Acknowledgement in Receipt of Addendum

FIRM NAME: _____

BY:(Printed) _____

BY:(Signature) _____ TITLE: _____

Note: A signed acknowledgement in receipt of this addendum **MUST** be included with your bid proposal.