

# ADDENDUM #1



**PROJECT:** WWTP Hydrogritter Replacement  
**BID NO:** 19-021  
**FROM:** David Bries, Utilities Manager  
**DATE:** June 20, 2019

---

## Questions and Answers

No Questions submitted

## Clarifications and Additions

1. It was requested that Kusters Water be considered and an equal equipment manufacturer for this project.

**Answer:** We reviewed the specifications for Kusters Water Model GC Grit Classifiers, and it meets the performance specifications for the application and is acceptable. All minimum detailed specifications outlined in the bid documents must be met. Manufacturer and contractor are responsible to insure the equipment will fit into the existing building, and properly mount to the existing base, piping and electrical systems.

2. It was requested that Envirodyne Model CCF Cyclogritter grit processing system be considered as an equal manufacturer for this project

**Answer:** We reviewed the specifications for Envirodyne Model CCF Cyclogritter grit processing system, and it meets the performance specifications for the application and is acceptable. All minimum detailed specifications outlined in the bid documents must be met. Manufacturer and contractor are responsible to insure the equipment will fit into the existing building, and properly mount to the existing base, piping and electrical systems.

3. Regardless of the manufacturer of the grit equipment, the Cyclone and Screw Classifier materials of construction for these items shall be as follows:  
A) Cyclone shall be painted fabricated steel or 304 stainless steel.  
B) Screw Classifier shall be made out of 304 stainless steel.

## Acknowledgement in Receipt of Addendum

FIRM NAME: \_\_\_\_\_

BY:(Printed) \_\_\_\_\_

BY:(Signature) \_\_\_\_\_ TITLE: \_\_\_\_\_

Note: A signed acknowledgement in receipt of this addendum **MUST** be included with your bid proposal.