

ADDENDUM #3



PROJECT: East Miami Waterline Replacement
BID NO: 19-037
FROM: Scott Murphy
DATE: October 22, 2019

Questions and Answers

1. *Does the AC pipe need to be tested as part of CDPHE's permitting requirements?*

Answer: No. Because the material is a known asbestos-containing material it does not need to be specifically tested as part of the permitting process.

Clarifications and Additions

1. None this addendum.

Plan Revision

1. The keyed notes on lines 6 through 9 are incorrect. All of these aggregates should include Keyed Note C indicating that all aggregates will be paid based on weigh tickets.
2. After meeting with the Museum of the Mountain West the project will be adding an additional fire hydrant near the entrance to the museum. **Please update the quantity for Line Item 18 (Fire Hydrant Assembly) to 2 qty on the bid form submitted with the bid.**

Acknowledgement in Receipt of Addendum

FIRM NAME: _____

BY:(Printed) _____

BY:(Signature) _____ TITLE: _____

Note: A signed acknowledgement in receipt of this addendum **MUST** be included with your bid proposal.