

# ADDENDUM #1



**PROJECT:** 6530 Bridge Deck Replacement  
**BID NO:** 19-043  
**FROM:** Ryan Cushenan  
**DATE:** December 19, 2019

---

## Questions and Answers

1. *Will the City require pedestrian access to be maintained along 6530 Road across the bridge sidewalk throughout construction?*

**Answer:** Due to the sidewalk being located within an active construction zone during all phases of construction, there is no practical means of maintaining safe passage for pedestrians and, as a result, the work area may be closed to pedestrians.

2. *Is the form work for the bridge deck adequate to support a deck machine?*

**Answer:** The current design is not intended to accommodate a deck machine.

## Clarifications and Additions

1. None this addendum

## Plan Revisions

1. None this addendum

## Acknowledgement in Receipt of Addendum

FIRM NAME: \_\_\_\_\_

BY:(Printed) \_\_\_\_\_

BY:(Signature) \_\_\_\_\_ TITLE: \_\_\_\_\_

Note: A signed acknowledgement in receipt of this addendum **MUST** be included with your bid proposal.