

## ADDENDUM #2

**PROJECT:** 2020 Manhole rehabilitation  
**BID NO:** 20-004  
**FROM:** Dustin Fisher  
**DATE:** June 24, 2020



---

### Questions and Answers.

1. Do you anticipate extending the bid due date?
  - a. There is no need to extend the due date for the Bid.
2. What additional details are you willing to provide, if any, beyond what is stated in bid documents concerning how you will identify the winning bid?
  - a. Award of the contract will be to the “Best” bid based on analysis of the bids submitted. No additional bid documents concerning how we will select the winning bid will be provided other than in Addendum form.
3. Was the bid posted to the bid notification website at [www.mygovwatch.com/free](http://www.mygovwatch.com/free)?
  - a. No
4. Other than your website, where was this bid posted?
  - a. This bid was posted on the City of Montrose website and a public notice was published in the Montrose Daily Press.
5. Geokrete geopolymer based on initial review may be considered. Bidder is required to provide a 10 year warranty for all materials and workmanship. The bidder needs to provide details of the proposed method of surface preparation to address removal of grease and other contaminants that are found in sanitary sewer systems and that meets the manufacturers recommendations for surface preparation and application of the products for this specific purpose.
6. Mainstay DS-5 and ML-72 based on initial review may be considered. Bidder is required to provide a 10 year warranty for all materials and workmanship. The bidder needs to provide details of the proposed method of surface preparation to address removal of grease and other contaminants that are found in sanitary sewer systems and that meets the manufacturers recommendations for surface preparation and application of the products for this specific purpose.

### Clarifications and Additions

Acknowledgement in Receipt of Addendum

FIRM NAME: \_\_\_\_\_

BY:(Printed) \_\_\_\_\_

BY:(Signature) \_\_\_\_\_ TITLE: \_\_\_\_\_