

ADDENDUM #1



PROJECT: Buckley/Lions Irrigation Replacement
BID NO: 21-031
FROM: Jackie Bubenik
DATE: January 4th, 2022

Questions and Answers

1. 4" #150 Z/PLT FLG KIT – QTY 2 I need to know what you are looking to have included in these kits. Flanges, bolts, nuts, gaskets? If so what kind of gaskets?

Answer: The kit comes separate from the flange and is all inclusive of what is needed to install.

2. 8" #150 Z/PLT FLG KIT – QTY 1 I need to know what you are looking to have included in these kits. Flanges, bolts, nuts, gaskets? If so what kind of gaskets?

Answer: The kit comes separate from the flange and is all inclusive of what is needed to install.

3. The Equivalent of Clemmons 600W 8" FL Screen I need to know what screen you are needing? Is this just a standard flanged filter screen?

Answer: 12 mesh is standard. No equivalent is accepted at this time.
<https://www.clemonssales.net/products/screens/clearwater-self-cleaning-suction-screen/>

Clarifications and Additions

1. None this addendum.

Plan Revisions

1. None this addendum.

Acknowledgement in Receipt of Addendum

FIRM NAME: _____

BY:(Printed) _____

BY:(Signature) _____ TITLE: _____

Note: A signed acknowledgement in receipt of this addendum **MUST** be included with your bid proposal.